



PLAN VIEW

CONSTRUCTION NOTES:

- ① STREET LIGHTING PULLBOX SHALL BE NO. (3-1/2) ELECTRICAL PULLBOX, DIMENSIONS OF 20"x14"x12".
- ② INTERCEPT EXISTING CONDUIT AND SPLICE WIRES TO EXTEND TO NEW POLE. SPLICES SHALL BE WATERPROOF.
- ③ CITY GALVANIZED STEEL CONDUIT WRAPPED WITH 20 MIL ELECTRICAL TAPE, AS OCCURRING TO/FROM NEXT STREETLIGHT POLE.
- ④ GALVANIZED STEEL CONDUIT SWEEP WRAPPED WITH 20 MIL ELECTRICAL TAPE WITH GROUND BUSHING.
- ⑤ INSTALL PULLBOX PER SCE REQUIREMENTS.
- ⑥ INSTALL CONDUIT PER UTILITY COMPANY STANDARDS.
- ⑦ POWER SHUTOFF SWITCH PULLBOX SHALL BE NO. (3-1/2) ELECTRICAL PULLBOX DIMENSIONS OF 20"x14"x12".
- ⑧ SCE POWER CONDUIT FROM POWER SOURCE.
- ⑨ SCE WIRES INSIDE POLE SHALL BE INSTALLED IN FLEXIBLE CONDUIT TO CELL EQUIPMENT.
- ⑩ CONDUCTORS FOR CITY LIGHTING SHALL BE ROUTED THROUGH POLE.
- ⑪ INSTALL COMMUNICATIONS PULLBOX PER UTILITY COMPANY REQUIREMENTS.

REVISED DATE _____ _____ _____ _____	CITY OF FULLERTON PUBLIC WORKS DEPARTMENT	DRAWN - _____ DATE 3/29/19
	SMALL CELL SITE LOW VOLTAGE POWER	STD. NO. 551 1 of 2
	APPROVED <i>[Signature]</i> CITY ENGINEER	DATE 4-12-19