



### LIST OF MATERIALS

- ① Main Size x 2" Tapped MJ Cap
- ② 2" Corp stop, M-IPTxCompression
- ③ 2" Copper coupling, compression
- ④ 2" Copper pipe (Type K, soft drawn)
- ⑤ 2" 90° Copper elbow, compression
- ⑥ 2" Brass coupling, M-IPTxCompression
- ⑦ 2" Blow-off ball valve, F-IPTxM-IPT
- ⑧ 2" Cap, F-IPT
- ⑨ 1" Meter box per Standard Drawing 601

### NOTES

1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.

## 2" BLOW-OFF ASSEMBLY



REVISIONS			
NO.	DATE	NO.	DATE
1	07/15/94	4	04/20/22
2	12/01/00		
3	02/29/16		

*[Signature]* 5/9/2022  
CITY ENGINEER DATE

*[Signature]* 5/24/2022  
PUBLIC WORKS DIRECTOR DATE

STANDARD DETAIL  
**621**  
SHEET 1 OF 1

DEPARTMENT OF PUBLIC WORKS