

LIST OF MATERIALS

- Main size x 4" DI tee, FLG
- 4" DI 45° elbow, FLG
- 103 456789 4" DI pipe or PVC DR14 pipe, FLG, cut to length Spool may be omitted and valve shall be flanged to 45° elbow if conditions allow
- 4" resilient—seat gate valve, FLG
- 4" DI pipe FLG x PE or PVC DR14 pipe PE x PE with flange adapter, cut to length
- 4" DI 90° elbow, MJ
- 4" Companion threaded flange
- 4" MNPT x MNST brass adapter
- 4" NST brass cap

NOTES

- 1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.
- 2. Pipe material to match main material or as directed by Engineer.

4" SAND BLOW-OFF ASSEMBLY

STANDARD DETAIL REVISIONS DATE DATE 624 02/26/17 01/26/94 12/01/00 09/24/19 SHEET 1 OF 1 02/29/16









DEPARTMENT OF PUBLIC WORKS