



LIST OF MATERIALS

- ① Stainless steel repair clamp

NOTES

1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.
2. City of Fullerton street excavation and water permit or approved set of water plans are required from the Public Works Department – Engineering Division (second floor of City Hall).
3. Customer must close account with Customer Service at (714) 738-6890. Contact the Water Meter Shop before water service is to be abandoned or construction begins. Water meter will be removed by City staff upon scheduling.
4. Location of corporation stop to be determined by Contractor.
5. Remove abandoned angle meter stop.
6. Water meter box to be removed:
 - a. Parkway – Fill hole with clean dirt and grade level.
 - b. Sidewalk – Sawcut to the closest score mark on each side of meter box and pour sidewalk to meet City Standards.
6. See Section 5-08.02 of these Specifications for shutdown of existing water main.

2" AND SMALLER SERVICE LATERAL ABANDONMENT



REVISIONS			
NO.	DATE	NO.	DATE
1	02/12/96	4	04/20/22
2	12/01/00		
3	02/29/16		

[Signature]
CITY ENGINEER 5/9/2022
DATE

[Signature]
PUBLIC WORKS DIRECTOR 5/24/2022
DATE

STANDARD DETAIL

646

SHEET 1 OF 1

DEPARTMENT OF PUBLIC WORKS