



LIST OF MATERIALS

- ① Cast iron cover with standard cover marking "WATER"
- ② Valve box
- ③ Riser Pipe – 8" PVC (C-900) pipe

NOTES

1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.
2. Backfill and resurface per Section 4 of these Specifications and as directed by Engineer.
3. Valve stem extensions required if depth to valve nut exceeds 4 feet, per Standard Drawing 651. The City shall approve all extensions.

STANDARD VALVE BOX ASSEMBLY



REVISIONS			
NO.	DATE	NO.	DATE
1	02/12/96	4	02/29/16
2	12/01/00	5	02/28/17
3	02/11/13	6	04/20/22

[Signature] 5/9/2022
CITY ENGINEER DATE

[Signature] 5/24/2022
PUBLIC WORKS DIRECTOR DATE

STANDARD DETAIL
650
SHEET 1 OF 1

DEPARTMENT OF PUBLIC WORKS