




#### LIST OF MATERIALS

- ① Steel valve stem extension

#### NOTES

1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.
2. Provide valve stem extension as required by Engineer.
3. Terminate extension 24" to 36" from finished grade.
4. No valve stem extension shall be less than 2 feet in length.
5. Fabricate extension to field measurement.
6. Provide additional locating ring when distance to bottom socket exceeds 5 feet.
7. The valve stem extension shall be of solid design, pinned couplers are unacceptable.
8. Stem shall not be pinned or attached by any other means to the valve nut.
9. See Section 5-10 of these Specifications for painting requirements.

### STEEL VALVE STEM EXTENSION

STANDARD DETAIL  <b>651</b>  SHEET 1 OF 1	REVISIONS				 CITY ENGINEER	5/9/2022 DATE	 PUBLIC WORKS DIRECTOR	5/24/2022 DATE	
	NO.	DATE	NO.	DATE					
	1	04/30/18	4	04/20/22					
	2	02/29/16							
	3	12/01/00							

DEPARTMENT OF PUBLIC WORKS