



LIST OF MATERIALS

- ① Tee (main size x lateral size) (MJ x MJ x FLG) for new main installation. For existing mains use stainless steel tapping sleeves
- ② Gate valve, (FLG x MJ) (pipe size)
- ③ DI pipe
- ④ If above ground service installation is not immediately installed with lateral installation, then 2" blow-off assembly will be required per Standard Drawing 621

NOTES

1. Refer to the City of Fullerton's Approved Materials List for approved manufacturers and model numbers.
2. All mechanical and push joints between main line and above ground service installation shall be restrained.
3. 45° elbows (M.J.) may be necessary to attain desired elevation behind curb. When fittings are needed to change elevation, restrain per Section 4-04 of these Specifications.

4" THROUGH 12" SERVICE LATERAL AND NEW MAIN INSTALLATION



REVISIONS			
NO.	DATE	NO.	DATE
1	12/01/00		
2	02/29/16		
3	04/20/22		

Steve R.
CITY ENGINEER
5/9/2022
DATE

Meg McWade
PUBLIC WORKS DIRECTOR
5/24/2022
DATE

STANDARD DETAIL

701

SHEET 1 OF 1

DEPARTMENT OF PUBLIC WORKS