




LIST OF MATERIALS

- ① Temporary water meter and backflow preventer (to be installed by City).
- ② 3" MIP x 2½" MIP hydrant adapter (to be installed by City).
- ③ Globe valve (to be installed by City).

TEMPORARY FIRE HYDRANT METER AND REDUCED PRESSURE BACKFLOW DEVICE

STANDARD DETAIL 735 SHEET 1 OF 1	REVISIONS				 CITY ENGINEER	5/9/2022 DATE	 PUBLIC WORKS DIRECTOR	5/24/2022 DATE	
	NO.	DATE	NO.	DATE					
	1	04/20/22							