


APRIL 16, 2018

CORRECTIVE MEASURES IMPLEMENTATION WORK PLAN
RAYTHEON COMPANY
FORMER HUGHES AIRCRAFT COMPANY

1901 WEST MALVERN AVENUE
FULLERTON, CALIFORNIA

PREPARED FOR:
RAYTHEON COMPANY



HARGIS + ASSOCIATES, INC.
HYDROGEOLOGY • ENGINEERING



HARGIS + ASSOCIATES, INC.

HYDROGEOLOGY • ENGINEERING

La Jolla Gateway
9171 Towne Centre Drive, Suite 375
San Diego, CA 92122
Phone: 858.455.6500
Fax: 858.455.6533

April 16, 2018

VIA FEDERAL EXPRESS STANDARD

Mr. Steve Rounds
CALIFORNIA ENVIRONMENTAL PROTECTION AGENCY
DEPARTMENT OF TOXIC SUBSTANCES CONTROL
Southern California Region
9211 Oakdale Avenue
Chatsworth, CA 91311-6520

Re: Transmittal of Corrective Measures Implementation Work Plan, Raytheon Company
(Former Hughes Aircraft Company) Facility, 1901 West Malvern Avenue, Fullerton, California


Dear Mr. Rounds:

Enclosed for your review is a hard copy and CD of the Corrective Measures Implementation Work Plan for the Raytheon Company (Former Hughes Aircraft Company) Facility located at 1901 West Malvern Avenue in Fullerton, California.

If you have any questions or require additional information, please contact us at 858-455-6500.

Sincerely,


HARGIS + ASSOCIATES, INC.



Christopher G.A. Ross, PG, CHG
Principal Hydrogeologist



Kevin L. Coons, PE
Senior Engineer



Steven P. Netto, PG 8030, CHG 872
Senior Hydrogeologist

CGAR/KLC/SNP/jak

Other Offices:
Folsom, CA
Mesa, AZ
Tucson, AZ



Mr. Steve Rounds
April 16, 2018
Page 2

cc w/encl: (1 copy w-CD)

Mr. Steve Rounds, Department of Toxic Substances Control, Chatsworth
Mr. Paul Pongetti, Department of Toxic Substances Control, Cypress
Mr. Paul E. Brewer, Raytheon Company
Mr. Dave Mark, Orange County Water District
Mr. Eric Silvers, Regency Centers

(2 copies w-CD)

Ms. Phuong Nguyen, City of Fullerton

(CD Only)

Ms. Hye Jin Lee, City of Fullerton

(via Email) (Hard Copies Provided Upon Request)

Mr. David Jacobs, City of Buena Park
Ms. Iris Lee, City of Buena Park
Mr. Josh Darbee, Regency Centers
Ms. Marnie Farcone, 1st Commercial Realty Group, Inc.
Mr. Tom Shapiro, TA Realty
Mr. Kendrick Leckband, TA Realty
Ms. Christine Ehrhardt, Greystar
Ms. Maureen Hill Collins, Haley & Aldrich, Inc.
Ms. Tizita Bekele, PE, Department of Toxic Substances Control, Cypress
Mr. Mike McGee, City of Buena Park
Ms. Carol Owens, Greystar
Ms. Kim Buss, Orange County Public Works – Flood Control District

(via Email only)

Ms. Tiffany Foo, City of Fullerton
Mr. Carl Bernhardt, California RWQCB, Santa Ana Region
Mr. Duc Nguyen, Orange County Public Works
Mr. Paul Rodolf, Hydraflow
Mr. Robinson Sioson, Hydraflow

CORRECTIVE MEASURES IMPLEMENTATION WORK PLAN

RAYTHEON COMPANY
(FORMER HUGHES AIRCRAFT COMPANY)
1901 WEST MALVERN AVENUE
FULLERTON, CALIFORNIA

TABLE OF CONTENTS

Section	Page
ACRONYMS AND ABBREVIATIONS.....	v
1. 0 INTRODUCTION.....	1
1.1 PURPOSE AND SCOPE	1
1.2 WORK PLAN OUTLINE	2
2. 0 CONCEPTUAL SITE MODEL	3
3. 0 CORRECTIVE MEASURES OBJECTIVES	6
4. 0 DESCRIPTION OF CORRECTIVE MEASURES.....	7
4.1 SELECTED REMEDY FOR GROUNDWATER	7
4.2 CORRECTIVE MEASURES CONTINGENCIES	9
5. 0 DATA SUFFICIENCY	11
6. 0 PROJECT MANAGEMENT	13
6.1 ROLES AND RESPONSIBILITIES	13
6.2 PROJECT SCHEDULE.....	14
7. 0 DESIGN CRITERIA/BASIS.....	16
8. 0 CONCEPTUAL DESIGN.....	18
8.1 EXTRACTION SYSTEM	18
8.1.1 Extraction Well Field.....	18
8.1.1.1 Extraction Well Locations	18
8.1.1.2 Extraction Pumping Rates.....	19
8.1.1.3 Estimated Concentration of COCs.....	19
8.1.1.4 Extraction Well Construction	19
8.1.1.5 Groundwater Extraction Well Pumps	20
8.1.1.6 Extraction Well Vaults	21
8.1.2 Extraction Conveyance Piping	21
8.1.2.1 Extraction Pipeline Construction	21
8.1.2.2 Extraction Pipeline Routing	22
8.1.3 Extraction Well Electrical Service.....	22
8.2 TREATMENT SYSTEM	23
8.2.1 Treatment Plant Location, Building Considerations and Materials of Construction	23
8.2.2 Treatment System Elements.....	24
8.2.2.1 Influent Storage Tank T-2001	24
8.2.2.2 Influent Transfer Pump P-2001	25
8.2.2.3 Particulate Filter F-2001	25
8.2.2.4 Advanced Oxidation System PA-2001	25
8.2.2.5 Liquid Phase Carbon Adsorption V-2001 and V-2002	26
8.2.2.6 Effluent Storage Tank T-2002.....	26
8.2.2.7 Injection Transfer Pump P-2002	26

TABLE OF CONTENTS (continued)

Section	Page
8.2.2.8 Utility Storage Tank T-4001 / Transfer Pump P-4001 / Particulate Filter F-4001	27
8.2.3 Treatment System and Well Field Control Summary	27
8.2.4 Utility Requirements	27
8.3 INJECTION SYSTEM	28
8.3.1 Injection Well Field	29
8.3.1.1 Injection Well Locations.....	29
8.3.1.2 Injection Rates	29
8.3.1.3 Injection Well Construction.....	29
8.3.1.4 Groundwater Injection Tubes	30
8.3.1.5 Injection Well Vaults	30
8.3.2 Injection Conveyance Piping.....	31
8.3.2.1 Injection Pipeline Construction.....	31
8.3.2.2 Injection Pipeline Routing.....	31
8.3.3 Injection Well Electrical Service	32
9.0 PROCESS FLEXIBILITY	33
10. 0 WASTE MANAGEMENT	34
11. 0 REQUIRED PERMITS	35
12. 0 REFERENCES.....	36

TABLE OF CONTENTS (continued)TABLES

Table

1	BASE AND CONTINGENCY CASE FLOWRATES, BASIS OF DESIGN
2	BASE AND CONTINGENCY CASE CONCENTRATIONS, BASIS OF DESIGN

FIGURES

Figure		Drawing Number
1	SITE LOCATION	410-8281 A
2	WELL AND PIEZOMETER LOCATIONS	410-9312 A
3	CONCEPTUAL SITE MODEL OVERVIEW, UNIT B/TARGET ZONE	220-2341 A
4	REGIONAL CONCEPTUAL GROUNDWATER MODEL HYDROGEOLOGIC CROSS-SECTION C-C'	310-1423 A
5	RECOMMENDED GROUNDWATER CORRECTIVE MEASURE	550-1135 A
6	ALTERNATIVE GW5A: ON-SITE AND BREA CREEK ALIGNMENT EXTRACTION WITH ON-SITE AND OFF-SITE UNIT B INJECTION SIMPLIFIED PROCESS FLOW DIAGRAM	560-0370 A
7	REGIONAL PRODUCTION WELLS	410-9833 A
8	ORGANIZATIONAL CHART	---
9	CORRECTIVE MEASURES IMPLEMENTATION SCHEDULE	---
10	ALTERNATIVE GW6A: ON-SITE AND SOUTH OF BREA CREEK EXTRACTION WITH ON- AND OFF-SITE DISTRIBUTED INJECTION	410-10011 A

ACRONYMS AND ABBREVIATIONS

1,1-DCE	1,1-dichloroethylene
AOP	advanced oxidation process
CACA	Corrective Action Consent Agreement
CMI	Corrective Measures Implementation
CMS	Corrective Measures Study
CMT	Corrective Measures Termination
COCs	compounds of concern
DCHDPE	double-contained high-density polyethylene
DTSC	Department of Toxic Substances Control
EHS	Environmental Health & Safety
EPA	Environmental Protection Agency
gpm	gallons per minute
GAC	granular active carbon
H ₂ O ₂	hydrogen peroxide
HAC	Hughes Aircraft Company
HDPE	high-density polyethylene
HOA	Homeowners Association
H+A	Hargis + Associates, Inc.
MCL	maximum contaminant level
OCWD	Orange County District
OCPW/FCD	Orange County Public Works / Flood Control District
O&M	Operation and Maintenance
OMM	operation, maintenance and monitoring
PLC	programmable logic controller
POCs	points of compliance
Psig	per square inch gauge
RAOs	Remedial Action Objectives
Raytheon	Raytheon Company
RCRA	Resource Conservation and Recovery Act
ROW	rights-of-way
RWQCB-SA	Regional Water Quality Control Board – Santa Ana
SCE	Southern California Edison
SDR	standard dimension ratio
the Site	1901 West Malvern Avenue, Fullerton, California
SWPPP	Storm Water Pollution Prevention Pla
SVOC	semi-volatile organic compounds
TCE	trichloroethylene
UV	ultraviolet
VFD	Variable Frequency Drive
VOC	volatile organic compounds
WDR	Waste Discharge Requirement

CORRECTIVE MEASURES IMPLEMENTATION WORK PLAN

RAYTHEON COMPANY
(FORMER HUGHES AIRCRAFT COMPANY)
1901 WEST MALVERN AVENUE
FULLERTON, CALIFORNIA

1.0 INTRODUCTION

This Resource Conservation and Recovery Act (RCRA) Corrective Measures Implementation (CMI) Work Plan has been prepared by Hargis + Associates, Inc. (H+A) on behalf of Raytheon Company (Raytheon) (formerly Hughes Aircraft Company [HAC]) for the Site located at 1901 West Malvern Avenue which is northeast of the intersection of Malvern Avenue and Gilbert Street in Fullerton, California (the Site) (Figure 1). This CMI Work Plan has been prepared in accordance with requirements of the Corrective Action Consent Agreement (CACA) between Raytheon and the California Environmental Protection Agency, Department of Toxic Substances Control (DTSC) of January 15, 2003 (DTSC, 2003).

1.1 PURPOSE AND SCOPE

This CMI Work Plan presents a strategy for the implementation of the selected corrective measures for groundwater impacted with volatile organic compounds (VOCs), primarily 1,1-dichloroethylene (1,1-DCE) and to a lesser extent trichloroethylene (TCE), and the semi-volatile organic compound (SVOC) 1,4-dioxane, associated with two former areas of the Site (former Building 609 area and former Building 601 area) (Figure 2) in accordance with the CACA as outlined in the Corrective Measures Study (CMS) and DTSC's Final Statement of Basis for the Site (Figure 3) (DTSC, 2018a and 2018b; H+A, 2015 and 2017).

1.2 WORK PLAN OUTLINE

This CMI Work Plan has been organized into the following sections:

- Section 1 provides an introduction, the overall purpose and scope of the CMI Work Plan, and an outline of the scope of this document;
- Section 2 outlines the Conceptual Site Model;
- Section 3 presents a Corrective Measures Objectives;
- Section 4 provides a description of the selected Corrective Measures;
- Section 5 provides a consideration of groundwater data sufficiency;
- Section 6 outlines project management and schedule;
- Section 7 outlines the Corrective Measures design criteria and basis;
- Section 8 provides a description of the Conceptual Design for the selected Corrective Measures;
- Section 9 outlines process flexibility requirements to accommodate contingencies in design and operation of treatment systems during CMI;
- Section 10 outlines waste management considerations;
- Section 11 lists required construction/building and operational permits; and
- Section 12 lists references cited.

2.0 CONCEPTUAL SITE MODEL

Groundwater impacts at the Site and a Conceptual Site Model have been summarized in the CMS (Figure 3) (H+A, 2015). Key elements of the Conceptual Site Model were summarized in the Statement of Basis as follows (DTSC, 2018b).

The Site is located on the southern portion of the West Coyote Hills in Fullerton, California. The Coyote Hills have formed due to complex folding and faulting in the area. The Conceptual Site Model includes the following key elements:

1. Relatively low concentrations of residual compounds of concern (COCs) are at the two former source areas. The primary COCs at former Building 609 area are 1,1-DCE and 1,4-dioxane. Prior remediation in this area significantly reduced both residual concentrations and mass in the soil underlying the former building and the perched zone (Northern Perched Zone). Residual COCs in the soil and the Northern Perched Zone enter a portion of the regional groundwater system near the southern terminus of the Northern Perched Zone (toe of perched zone) [Figure 3]. The primary COCs at former Building 601 area are TCE and 1,1-DCE. There is no perched zone in the vicinity of the Building 601 area; therefore, the residual COCs from this former source area enter a portion of the regional groundwater system near the southwest corner of former Building 601. The results of prior health risk assessments at both of these former source areas and the area overlying the Northern Perched Zone coupled with the depth to regional groundwater (over 100 feet below land surface [bls]) indicate that the only potential pathway for human exposure to COCs is from groundwater extraction from the portions of the regional aquifer system containing COCs. No groundwater use, other than for sole purposes of treatment, is allowed on the Site.
2. Residual COCs enter portions of the regional groundwater in two general areas:
 - a) at the toe of the perched zone south of former Building 609 and b) in the vicinity of the southwest corner of former Building 601. The hydrostratigraphic units within the regional groundwater system slope (dip) to the south in the area north of Malvern Avenue due to deep faulting in this area [Figure 4]. The primary transport zone within the regional groundwater system for COCs from both of the areas is a

relatively coarse zone referred to as “Unit B” or the “Target Zone”. Given the dip of the hydrostratigraphic units north of Malvern Avenue and the depth of the regional groundwater table (first groundwater in regional groundwater system), the depth to first groundwater in Unit B near the toe of the perched zone and southwest corner of Building 601 is about 120 feet bls. The depth to Unit B is approximately 1,000 feet bls south of these two areas along Malvern Avenue. North of these two areas Unit B becomes unsaturated.

3. Once the COCs have entered respective portions of the regional groundwater system, the COCs appear to be transported to the west at and near the Site and appear to be transported in a more southwesterly direction farther downgradient from the Site. The COCs remain in Unit B downgradient from the Site due to the lower water level elevations in Unit B as compared to water level elevations in overlying and underlying hydrostratigraphic units. Given the preferential transport within Unit B, the depth to groundwater containing COCs increases as one approaches Malvern Avenue, such that the COCs are encountered at depths of approximately 1,000 feet bls in groundwater near and to the south of Malvern Avenue.
4. Well 9 (also sometimes referred to as F-AIRP) is located at the Fullerton Municipal Airport approximately 4,000 feet downgradient of the Site boundary. Unit B is within the deepest screen interval of this well. Although 1,1-DCE is present in the deepest screened zone in Well 9, it has been historically detected below the drinking water maximum contaminant level (MCL), and as such meets drinking water standards of protection for human health established by Federal and State agencies. Depth-specific sampling of Well 9 was conducted in April and May 2014 by Raytheon with cooperation and input from the City of Fullerton and the Orange County Water District (OCWD). In addition, packer testing of Well 9 was completed in 2016. The results of depth-specific sampling and packer testing indicate that 1,1 DCE appears to be entering Well 9 from the lowermost two screen intervals and not from the uppermost or intermediate screen intervals. The concentration of 1,1-DCE and TCE detected from the deepest screen interval during depth-specific sampling was less than the drinking water MCL. TCE was not detected in the wellhead samples collected from Well 9, which represents a composite sample of water contributed from all screen intervals. 1,4-Dioxane was not detected in groundwater

samples collected as part of the depth-specific sampling program or in wellhead samples during the packer testing program.

Operations of the current pilot groundwater extraction and treatment system have reduced the COC mass in the regional groundwater and have reduced off-site migration of COCs.

3.0 CORRECTIVE MEASURES OBJECTIVES

Corrective Measures Objectives include general and specific Remedial Action Objectives (RAOs) for groundwater. General RAOs for groundwater at the Site are to protect human health and the environment. Specific RAOs for groundwater were outlined in the CMS and reiterated Statement of Basis:

- Prevent unacceptable exposure to groundwater containing COCs;
- Establish containment areas within the regional groundwater system to control future residual COC migration from former source areas; and
- Contain COCs in groundwater to protect current and future uses of groundwater with a short-term goal of not exceeding Federal and California State drinking water MCLs at points of compliance (POCs) and a long-term goal of attaining drinking water MCLs in groundwater to the extent practical.

Corrective measures for groundwater were evaluated in the CMS Report with respect to the RAOs for groundwater listed above and the following drinking water standards at existing and potential receptors: Federal and California State drinking water MCLs and California Notification Levels (H+A, 2015).

4.0 DESCRIPTION OF CORRECTIVE MEASURES

The recommended groundwater corrective measures alternatives presented in the CMS were selected by the DTSC as outlined in the Final Statement of Basis (DTSC, 2018a and 2018b; H+A, 2015 and 2017). The following sections summarize the selected corrective measures for the Site as presented in the CMS and summarized in the Final Statement of Basis.

4.1 SELECTED REMEDY FOR GROUNDWATER

The selected remedy for the Site was developed using the retained groundwater corrective measures alternatives outlined in the CMS Report and incorporates respective contingency actions to ensure that proposed groundwater RAOs are met (H+A 2015).

The selected groundwater remedy is On-Site and Brea Creek Alignment Extraction with On- and Off-Site Injection of treated groundwater into the Unit B (CMS Alternative GW5A; Figure 5). The selected remedy also includes a provision for non-potable reuse of the treated groundwater while maintaining some off-site injection of treated groundwater into the Unit B (CMS Alternative GW5B). The CMS indicates that if non-potable reuse is incorporated into the remedy, the extracted groundwater would be treated to standards required as part of the Waste Discharge Requirements (WDR) permit for groundwater reinjection issued by the Regional Water Quality Control Board, Santa Ana (RWQCB-SA). The treated water would be provided to the purveyor of non-potable water who is responsible for the construction, permitting, and operation of the non-potable distribution system. In addition, any tertiary treatment exceeding WDR standards that may be required for non-potable reuse will be the responsibility of the water purveyor. The determination of whether non-potable water reuse will be incorporated into the remedy will be made by Raytheon and the purveyor of non-potable water during the CMI design. At this time, it is not expected that non-potable water reuse would be incorporated into the CMI design. However, this determination could also be made at some time in the future after CMI design is complete as long as the initial CMI design incorporated an injection wellfield with sufficient capacity to accept the entire volume of groundwater extracted and treated.

The selected remedy will extract groundwater using five existing wells, EW-01, EW-02, MW-21, MW-29, MW-31, and four proposed extraction wells nominally identified as EW-03, EW-04,

EW-06, and EW-07, at a total design flowrate of 490 gallons per minute (gpm) (Figure 5). The five existing wells and proposed extraction well EW-07 are located on-Site. Proposed extraction wells EW-03, EW-04, and EW-06 are located off-site. The location and target zone for injection wells is relatively flexible; however, the selected remedy conceptually incorporates reinjection into Unit B on the southeast portion of the Site (IW-01 and IW-02), and in the residential neighborhood to the west of the Site (IW-03 to IW-05).

There are two potential locations for groundwater treatment systems. The groundwater corrective measure alternative allows for use of one or both of these treatment system locations. At this time, it is anticipated that the treatment location to be incorporated into the CMI design is in the general vicinity of the existing pilot groundwater treatment system. The treatment processes would include filtration of groundwater followed by an Advanced Oxidation Process (AOP) to treat 1,4-dioxane and some of the VOCs, followed by liquid-phase granular activated carbon (GAC) to serve as a final polish for VOC treatment and for reduction of residual hydrogen peroxide (H_2O_2) from the AOP (Figure 6). The AOP that will be used in the treatment system employs ultraviolet (UV) light and H_2O_2 . This configuration is currently being used as part of the pilot groundwater extraction and treatment system located at the Site.

The Institutional Controls for the selected groundwater corrective measure alternative consist of the following:

- deed restrictions to prohibit future well installations at the Site, with exception of wells installed as part of the groundwater corrective measures, thereby minimizing potential risks of exposure;
- submittal of system performance reports to nearby water users (Cities of Fullerton and Buena Park);
- annual review of water production and water quality data from Fullerton Well 9 and Buena Park BP-SM1;
- annual review of well permits issued in areas from near the Site to within 0.5 mile of point-of-compliance wells to determine if new groundwater extraction wells have been installed in the area;
- annual review of water production from OCWD for selected wells in the Site vicinity (identified on Figure 7) and any other new production wells that may be installed in this vicinity.

It is anticipated that off-site groundwater will meet RAOs prior to on-site groundwater, in which case the off-site extraction wells could be turned off while on-site extraction wells continue to operate until RAOs are met in on-site groundwater as well. Upon substantially meeting RAOs, a Corrective Measures Completion report will be prepared and submitted to the DTSC recommending Corrective Measures Termination (CMT). Following DTSC approval of CMT, the treatment system will be demobilized. Demobilization will include teardown of remediation system equipment, decommission of the extraction/collection system, and removal of equipment from the Site.

4.2 CORRECTIVE MEASURES CONTINGENCIES

Contingencies for groundwater corrective measures may be implemented in order to address specific human health or environmental concerns or may be implemented to modify the scope of the respective program in response to changes in field conditions or observations during CMI, thus increasing the flexibility of the respective corrective measure based on an ongoing evaluation of the results of the associated monitoring programs.

The following outlines a description of contingencies along with associated triggers for the selected groundwater corrective alternative described above. The initial contingency action would be implemented first with the secondary contingency action being implemented if the initial does not achieve performance requirements. The decision analysis for contingency actions associated with groundwater corrective measures alternatives were outlined in the CMS.

Four contingency actions have been identified for the on- and off-site portions of the selected groundwater corrective measures as summarized in the following:

IDENTIFIER	TRIGGER	INITIAL CONTINGENCY ACTION	SECONDARY CONTINGENCY ACTION
GW5/6a	Increasing concentration trends in one or more of the POC monitor wells at end of first 5 years of monitoring	Evaluate increasing extraction rate at existing off-site extraction wells	Add additional off-site extraction wells
GW5/6b	Fullerton Well 9 exceeds 50 percent of MCL for more than 6 months	Isolate Unit B in Well 9 and monitor AND evaluate increasing extraction rate at existing off-site extraction wells or adding an additional off-site extraction well	Assess alternate sources of potable water OR relocate well
GW5/6c	Water level, model simulations and/or long-term water quality trend indicating on-site containment not adequate	Evaluate increasing extraction rate at existing on-site extraction wells	Add additional on-site extraction wells
GW5/6d	Water level, model simulations and/or long-term water quality trend indicating off-site containment not adequate	Evaluate increasing extraction rate at existing off-site extraction wells	Add additional off-site extraction wells

In addition, there is some uncertainty as to: 1) the ability to obtain access for extraction wells and/or associated pipeline along the Brea Creek Alignment; and/or 2) the ability to obtain access / install injection pipelines in the residential neighborhood to the west of the Site; as such the preferred alternative may be modified during the CMI design.

5.0 DATA SUFFICIENCY

CMS supporting activities have been conducted in accordance with the CMS and Groundwater Assessment work plans and associated addenda since the initial 2003 CMS Work Plan was prepared. These activities included groundwater monitoring and assessment, groundwater treatment bench-testing and extended groundwater extraction and treatment pilot testing, and numerical groundwater monitoring. These activities were conducted to provide sufficient data to support completion of the groundwater assessment and evaluation of groundwater corrective measures alternatives as summarized in the CMS Report (H+A, 2015). The sufficiency of existing groundwater data collected at the Site to support the corrective measures design is considered below.

Routine groundwater monitoring has been conducted quarterly since 2003. Additional groundwater assessment was conducted in several phases between 2003 and 2014, in accordance with multiple addenda of the Additional Groundwater Assessment Work Plan that have been implemented at the Site. Monitor wells have been installed to more fully delineate the distribution of VOCs, principally 1,1-DCE and 1,4-dioxane, in the Target Zone (H+A, 2003, 2004, 2008, 2010, 2011, 2013a, 2013b, and 2014). Results from the additional groundwater assessments completed through 2014 and ongoing groundwater monitoring indicate that groundwater assessment is sufficiently complete (H+A, 2018). Note that an additional monitor well installation is planned as an additional downgradient POC monitoring location during CMI. Also, an additional monitor well is planned to be installed in the vicinity of Fullerton Well 9. The monitor wells will be installed prior to start-up of the groundwater corrective measure.

Several field and bench tests evaluating various groundwater treatment technologies have been conducted since 2004 and an extended groundwater extraction and treatment pilot test has been operating at the Site since 2008 (H+A, 2015 and 2018). The current AOP treatment technology uses UV light and H_2O_2 and is followed by GAC as a polishing step in the treatment process. The current treatment process is effectively removing VOCs and 1,4-dioxane from extracted groundwater, and has maintained the treatment goals of Federal and California State drinking water MCLs for VOCs, and the California Notification Level for 1,4-dioxane since installation of the technology. Hydraulic testing, groundwater capture zone analysis and groundwater modeling suggest extraction is effective for capture of groundwater at the Site. Results from the ongoing groundwater extraction and treatment pilot testing indicate existing data are sufficient to support CMI design.

6.0 PROJECT MANAGEMENT

Project management, including project organization, roles responsibilities and the estimated project schedule are included in the following sections.

6.1 ROLES AND RESPONSIBILITIES

The following outlines general roles, responsibilities and qualifications for primary elements of the CMI. An Organizational Chart has been prepared (Figure 8).

COMPANY	PERSON	ROLE	QUALIFICATION
Raytheon Company	Paul Brewer	Project Manager, Primary Project Contact	Engineering Specialist, Site Environment, Health & Safety (EHS) Specialist
	Daniel Samorano, PE	Manager Remediation Programs, Corporate EHS	Professional Engineer
H+A	Chris Ross, PG, CHG	Senior Project Management, Principal, Technical Review	Professional Geologist
	Steve Netto, PG, CHG	Project Management CMI Oversight	Professional Geologist
	Kevin Coons, PE	Engineering Design/Review; CMI Oversight	Professional Engineer
	Steve Stewart Ross Horton	CMI construction oversight and OMM	Engineer
	Tyler Evans, PG	CMI well installation oversight and OMM	Professional Geologist
Licensed Environmental Construction Contractor	---	Treatment system/ pipeline construction implementation	General Contractor's License
Licensed Environmental Well Drilling Contractor	---	Drilling/Well Construction implementation	C57 License

Primary lines of communication will be between Raytheon and Raytheon's project management/CMI oversight contractor (H+A), who will work as an extension of Raytheon and will communicate directly with well installation and general construction contractors. H+A will also support Raytheon in communications with property owners. Lines of communication between contractors and property owners, property managers, and tenants will be channeled through Raytheon or H+A.

6.2 PROJECT SCHEDULE

An estimated project schedule for CMI has been prepared (Figure 9). The project schedule presents key milestones and deliverables and includes the following components:

- CMI Work Plan, which outlines Conceptual Design including schedule, sequencing and deliverables associated with the CMI;
- The design process includes Final Plans and Specifications; Updated Cost Estimate; and Construction Completion Report, along with submittal of Final Plans to obtain construction permits. Note, to stream line process, the specifications will include information presented in a Construction Work Plan, such that a formal Construction Work Plan will not be required;
- The Operations and Maintenance Plan and operating permits are integrated to maximize schedule efficiencies;
- Operation, maintenance and monitoring (OMM) of the corrective measure includes start-up of the system and long-term OMM including periodic monitoring reports.

A critical pathway to the overall schedule is access to off-site public and private properties. CMI design and construction/building permitting cannot be completed until substantial agreement on the off-site property access from the respective property owners are obtained (Figure 9). On-site access was maintained through sale of the Site property, and Raytheon has met with the primary on-site property owners to present the conceptual CMI plans. However, there is uncertainty regarding access to install and operate proposed corrective measures infrastructure on off-site properties. Current uncertainties include: 1) the ability to obtain access from: the Orange County Public Works / Flood Control District (OCPW/FCD) for extraction wells and/or associated pipeline along the Brea Creek Alignment; 2) a private bridge owner to span the pipeline across Brea Creek; and 3) a private Home Owners Association (HOA) and/or the City of Fullerton to install injection wells and pipelines in the residential neighborhood to the west of the Site. As such, the preferred alternative may be modified, and therefore, completion of off-site access to confirm final well locations and pipeline routing is a predecessor to completing the design.

The process to request access from OCPW/FCD and the City of Fullerton has been initiated. If denied access to Brea Creek, off-site extraction wells and pipeline would be located south of Brea Creek, however at locations that are less effective and efficient to the overall remedy. If substantial agreement with OCPW/FCD is reached, Raytheon will pursue access to the private bridge crossing over Brea Creek, and if access to the private bridge is denied, Raytheon would construct a separate utility bridge over Brea Creek Channel. Raytheon is planning to contact the private HOA to coordinate access during the second and third quarters of 2018. If access is denied by the HOA of the residential neighborhood to the west of the Site, the injection wells and pipeline would be located only within City of Fullerton streets. Raytheon will continue to pursue access to the off-site properties, however, the timing of the access approvals is somewhat out of the direct control of Raytheon, and therefore, there is uncertainty in the overall schedule for design, permit and construction of the CMI.

7.0 DESIGN CRITERIA/BASIS

Design criteria, design basis, and performance requirements for the groundwater corrective measures are outlined as follows:

- On-site and off-site plume capture pump and treat
 - Hydraulically contain on-site groundwater exceeding drinking water MCLs for VOCs and 1,4-dioxane and hydraulically capture off-site plume, to the extent practicable.
 - Location and pumping rates of extraction wells evaluated by numerical modeling of groundwater flow and aquifer testing;
 - Six on-site extraction wells located along downgradient Site boundary and toe of the perched zone with combined projected extraction rate of approximately 190 gpm.
 - Three off-site extraction wells with combined projected extraction rate of approximately 300 gpm.
 - Extraction wells screened within the Unit B.
 - Treated water to be returned to groundwater via on- and off-site injection wells. Sanitary sewer connection to be maintained for short-term temporary discharges of up to 50 gpm, primarily for treatment system testing purposes. Treated water may be split to provide non-potable use of portion of treated water in the future.
 - Two on-site injection wells to operate at a combined injection rate of 190 gpm.
 - Three injection wells off-site to operate at a combined injection rate of 300 gpm.
 - Extracted groundwater to be treated for VOCs and 1,4-dioxane through an AOP utilizing UV light and H₂O₂ followed by liquid-phase GAC as a polish to remove remaining VOCs following the AOP at a projected combined extraction rate of 490 gpm. Treatment system to be designed and constructed to accommodate a contingency to scale-up the AOP and liquid-phase GAC treatment should it become necessary.
 - Generally, below-grade infrastructure including new extraction wells and extraction conveyance piping and electrical conduits will be designed to accommodate contingency flowrates and electrical demands. Contingency flow rates for wells

and pipelines are generally 150 percent to 200 percent of the planned Base Case flowrates that were determined from model projections. Select above-grade treatment equipment will be designed with a capacity of approximately 150 percent over the planned Base Case flowrate capacity, to accommodate increased flow, should it become required.

- Preferred system up-time goal of 90 percent; minimum system up-time goal of 70 percent;
- Automated alarm notification system with automated system shutdowns to be included in system design.
- Anticipated remedy duration of one to several decades based on numeric modeling to achieve MCLs in groundwater, to the extent practicable.
- Contingencies are built in to corrective measure to adjust pumping rates and/or expand extraction wellfield further downgradient, if needed. In addition, contingencies allow for locating off-site wells to wherever access can be obtained, such as locating off-site extraction wells south of Brea Creek if access to Brea Creek cannot be obtained. Contingencies are designed to provide levels of flexibility in selected corrective measure.
- One existing monitor well and one proposed new monitor well to be installed are selected as downgradient points of compliance.

8.0 CONCEPTUAL DESIGN

This section describes design elements of the preferred groundwater corrective action alternative GW5A. The design elements have been grouped into the following elements: extraction system; treatment system; and the injection system.

There are two key terms used to describe Basis of Design for different design elements of the groundwater corrective action: 1) Base Case; and 2) Contingency Case. The Base Case refers to parameters such as flow and/or concentration, which are based on the CMS model projections (flow) and/or currently available groundwater quality data (concentration). The Contingency Case refers to increases to Base Case respective parameters that attempt to capture and incorporate some of the uncertainties associated with those parameters as basis of design for specific design elements.

8.1 EXTRACTION SYSTEM

The extraction system consists of the following major elements: extraction well field; conveyance pipelines and electrical as described further in the following sections.

8.1.1 Extraction Well Field

The location, extraction pumping rates, estimated COC concentrations, extraction well construction, extraction pumps and extraction well vaults are described in the following sections.

8.1.1.1 Extraction Well Locations

The general locations of the extraction wells are based upon the CMS Report (H+A, 2015). Groundwater will be extracted using five existing wells, EW-01, EW-02, MW 21, MW-29, MW-31, and four proposed extraction wells EW-03, EW-04, EW-06, and EW 07 (Figure 5). The location of the proposed extraction wells may be adjusted during design process to accommodate access

constraints. It is also possible that the off-site extraction wellfield may be modified if access to Brea Creek Channel alignment is not feasible (Alternative GW-6A, Figure 10).

At this stage in the design, alternative GW-5A serves as the basis of design for the locations of the extraction wells (Figure 5).

8.1.1.2 Extraction Pumping Rates

The Base Case extraction rates for alternative GW-5A are based on CMS Report modeling and are summarized in Table 1. The total Base Case extraction rate is 490 gpm. The Contingency Case extraction rates for alternative GW-5A are summarized in Table 1.

The Base Case or Contingency extraction rates are used as Basis of Design for different design elements as described in the respective sections below and are summarized in Table 1.

8.1.1.3 Estimated Concentration of COCs

The concentrations of primary COCs for each of the extraction wells has been estimated based on average concentrations in the respective well, a nearby well or a group of monitor wells (Table 2). The average concentration for each well was rounded up to one significant figure.

The average concentrations of compounds for each extraction well were used to estimate the influent concentration to the treatment system (refer to respective treatment system sections below).

8.1.1.4 Extraction Well Construction

Five of the nine extraction wells have already been constructed. Four of these five wells are or have been operated as part of the pilot groundwater extraction system (Figure 5). The four remaining extraction wells will be installed by a licensed drilling contractor to the targeted extraction interval. The extraction well installation will be conducted in compliance with the California Department of Water Resources and California Well Standards. The design life for the

new extraction wells will be 30 years given the challenges in constructing deep wells in off-site locations. As such, each extraction well will be constructed of stainless steel well screen and either stainless steel or high strength low alloy steel blank casing. The minimum casing diameter will be 6 inches based on inside diameter of casing to allow installation of downhole equipment. Centralizers will be installed to center the well casing within the borehole. Well construction details will be shown in the specifications as part of the final design.

8.1.1.5 Groundwater Extraction Well Pumps

Groundwater extraction rates for each extraction well were based on the Base Case extraction rates for the respective wells (Table 1). The pumps will be sized to extract groundwater from the respective extraction well to the treatment system without the need for booster pumps. If higher extraction rates (up to the Contingency Case) are required based on results of performance monitoring during operations and monitoring (O&M), then the pump would be upsized to accomplish the increased extraction rate.

A hydraulic model of the groundwater extraction system will be developed to allow the extraction system pumps to overcome frictional losses in the pipeline and deliver the water to the treatment plant, including overcoming the height of the influent storage tank.

Each extraction pump will be constructed of stainless steel material. Extraction rate-flow control will be provided by a Variable Frequency Drive (VFD) located in an adjacent well distribution and control panel. The VFD will speed up or slow down the pump motor to maintain flow at any set point within the pump's range of operation. This arrangement gives flexibility to the output flow of the individual pumps. The pumps will be operated to maintain a pre-set extraction flowrate, with shutdown based on water levels in the extraction wells to prevent running the pumps dry, as well as levels in the receiving tanks at the treatment plant to prevent overflows, and flow balancing with the injection wellfield. Each pump will include interlocks that will shut down the pump based upon high or low pressure and high or low flow set points. The final design of the pump installation will include provisions for pump cooling and may require shrouds in certain wells to maximize flow past the pump motor for cooling purposes. The extraction pumps for extraction wells with screen interval at or near the water table will be located in the screened interval allowing for maximum operational flexibility. The extraction pumps for the deeper extraction wells will be set above the

screened interval and approximately 100 feet below anticipated pumping levels to account for seasonal variations. Pump set depths will be included in the Final Design Drawings.

8.1.1.6 Extraction Well Vaults

Extraction wellheads will be located in below grade pre-cast concrete vaults. The wellhead casing will extend into the vault. Each vault lid will include an appropriate traffic-rating for protection and provide unobstructed access to the components within the vaults. The vaults will be designed to minimize surface water from entering vault. Vaults will have concrete bottom to contain and detect leaks, however there will be a drain with plug to allow surface water collected during rain events to empty out, if necessary.

Well pipe and vault piping will be stainless steel and will transition to double-contained high-density polyethylene (DCHDPE) as the piping exits the well vault. Stainless steel piping in the vault will be sized based on the Base Case extraction rate for the respective extraction well. Stainless steel pipe is the preferred material because it is rigid and resists corrosion. Well vaults will be sized to accommodate the Contingency Case flow rates and larger vault piping.

8.1.2 Extraction Conveyance Piping

The extraction pipeline construction and pipeline routing are described in the following sections.

8.1.2.1 Extraction Pipeline Construction

DCHDPE pipe will be utilized for underground extraction pipelines throughout the system in order to provide secondary containment during groundwater conveyance. DCHDPE pipe is easier to install than other traditional piping materials and is cost effective, flexible, durable, and corrosion resistant. The underground carrier piping shall be standard dimension ratio (SDR) SDR 11 with a maximum recommended operating pressure of 160 pounds per square inch gauge (psig) at 73 degrees Fahrenheit (°F). The underground containment piping shall be high-density polyethylene (HDPE) SDR 17 with a maximum recommended operating pressure of 100 psig at

73°F. The DCHDPE pipe will originate from within each vault and will convey the groundwater from each vault to the groundwater treatment system. On- and off-site extraction pipelines will combine into a single manifold at the treatment plant for transmission to the treatment plant equipment.

The majority of the pipeline will be installed underground. In locations where the pipeline will be above ground at bridge crossings, the DCHDPE will transition to double-contained Centricast CL-1520® fiberglass piping. Double-contained Centricast piping was chosen because of material strength and thermal expansion properties. At the treatment plant, the DCHDPE will transition to single-wall corrosion-resistant piping and secondary containment will be achieved by way of the treatment plant building and concrete slab floor.

The Basis of Design for sizing pipelines incorporates Contingency Case extraction rates from respective extraction wells (Table 1) and maintaining pipeline velocities less than 7 feet per second and greater than 2 feet per second.

8.1.2.2 Extraction Pipeline Routing

The majority of the pipe routing will be located on-Site, within public rights-of-way (ROWs) and the OCPW-FCD easement along Brea Creek Channel (Figure 5). To the extent possible, routing of pipeline along arterial streets (Gilbert and Malvern) will be minimized to reduce impact on residents/businesses and reduce traffic related risks. The routing may be refined or revised based on preliminary designs and access considerations currently being pursued with the OCPW-FCD and City of Fullerton.

8.1.3 Extraction Well Electrical Service

The two extraction wells located in close proximity to the treatment plant location (EW-01 and MW-21) will be powered from the treatment plant using a new 480 volt service. Extraction well MW-29 is currently operated as part of the pilot treatment plant and is connected to a satellite power station. Neither the existing downhole equipment nor electrical service at this location require upgrades or modifications. Extraction well EW-02 is currently operated as part of the pilot treatment plant with a 50 gpm, 220 volt three (3) phase submersible pump connected

to a satellite power station. The submersible pump in this well will be replaced with a 100 gpm 480 volt 3 phase submersible pump. The existing electrical service does not appear to require upgrades with possible exception of upsizing wire between the transformer and extraction well.

On-site extraction well EW-07 is a relatively low rate extraction well and is located in a residential development. It is anticipated that 480 volt, 3 phase power for this extraction well's submersible pump will be powered from a satellite station located nearby. The remaining extraction wells (on-site EW-31 and off-site EW-03, EW-04 and EW-06) will also be powered and controlled from individual local satellite stations. It is anticipated these submersible pumps will be 480 volt, 3 phase power.

The new satellite power stations will be located in non-traffic areas and will be sized to meet the Contingency Case extraction rates for their respective extraction wells (Table 1).

8.2 TREATMENT SYSTEM

The treatment system is designed to reduce concentrations of COCs in extracted groundwater to levels that comply with the RWQCB-SA general WDR permit for reinjection of treated groundwater. The simplified process flow diagram for alternative GW5A has been prepared (Figure 6).

The following sections describe the Basis of Design for: treatment plant location/building and materials of construction; selected elements of the treatment plant; treatment plant and well field control summary; and utility requirements.

8.2.1 Treatment Plant Location, Building Considerations and Materials of Construction

The CMS was flexible and allowed for one or two treatment plants. The two locations for the treatment plants are: in the vicinity of the existing pilot treatment plant; and the existing former HAC Building 684 treatment plant located to the south of Malvern Avenue and to the west of Gilbert Street, adjacent to monitor well MW-32 (Figure 5). Assuming access is available along Brea Creek Alignment and it is feasible to cross Malvern Avenue, the preferred location of the

proposed treatment plant is in the vicinity of the existing pilot treatment plant as access is reasonably available in this area and the existing Property Sales Agreement provides for this type of activity. As such, this location is the current Basis of Design for the treatment plant.

The treatment plant equipment will be located on a raised concrete containment dike within a prefabricated metal building or a concrete masonry block wall building. The building specifications will be developed during design and incorporate current property owner requirements.

The groundwater corrective action is expected to be operated continuously for over 30 years. Pressure vessels, tanks, and process pipelines will be designed and specified to have a design life of 30 years, typical for remediation systems. Mechanical equipment utilized (i.e., pumps, valve, controllers, etc.), the control system, and the advanced oxidation system are not expected to last the entire period of operation and so will be designed and specified in a manner that replacement can be readily performed as this equipment reaches the end of its useful life.

The preliminary construction materials for above ground process pipe within the treatment plant will most likely be single-wall corrosion-resistant piping for both untreated and treated water, however material selections may change during the corrective measures design process, which includes evaluation of cost and commercial availability.

8.2.2 Treatment System Elements

8.2.2.1 Influent Storage Tank T-2001

The influent storage tank T-2001 will receive unfiltered groundwater from the on- and off-site extraction wells and filtered water from the utility tank (T-4001) (Figure 6). The influent storage tank will be stainless steel or fiberglass. This tank will be designed for atmospheric pressure with a minimum of 15 minutes hydraulic residence time (the Contingency Case, Table 1). The tank will include level sensors that will be used in the control system to maintain a constant level in the tank. Since the influent storage tank has the largest volume of untreated groundwater, it will be evaluated in accordance with South Coast Air Quality Management District Rule 219 to determine whether the tank would be conditionally exempt from emission control requirements based on emissions being below respective thresholds.

8.2.2.2 Influent Transfer Pump P-2001

The water from the influent storage tank T-2001 is pumped through a particulate filter F-2001 (Figure 6). The influent centrifugal transfer pump is sized to handle the Base Case 490 gpm process stream flow (Table 1). The pump pad for the influent centrifugal transfer pump will be designed to accommodate a larger replacement transfer pump to handle the Contingency Case flow of 750 gpm. The transfer pump will be controlled using a VFD to match the treatment plant flowrate to that being produced by the extraction wellfield and being processed by the advanced oxidation system.

8.2.2.3 Particulate Filter F-2001

Extracted groundwater from the on- and off-site extraction wells will be pumped from the influent storage tank T-2001 through particulate filter F-2001 to the advanced oxidation system PA-2001 (Figure 6). The filter will be designed to remove particles 10 microns and larger. The particulate filter will have a stainless steel housing and hydraulic capacity of 750 gpm and a pressure rating of 150 psig. The particulate filter system would operate at a maximum recommended differential pressure (high pressure alarm setting) to prevent filter bag failure.

8.2.2.4 Advanced Oxidation System PA-2001

Extracted groundwater from the on- and off-site extraction wells will be pumped from the influent storage tank T-2001 through particulate filter F-2001 to advanced oxidation system PA-2001 (Figure 6). The advanced oxidation system currently used at the pilot treatment system for destruction of 1,4-dioxane and chlorinated alkenes dissolved in groundwater is the Trojan UVPhox™ Model 12AL30 developed by Trojan Technologies which uses UV light in combination with H_2O_2 . The new advanced oxidation system will be supplied by Trojan Technologies and be designed to destroy 1,4-dioxane from the estimated influent concentration (Table 2) to approximately 0.5 micrograms per liter (50 percent of the RWQCB-SA WDR Permit level for 1,4-dioxane) at 490 gpm (Base Case flowrate, Table 1). An additional AOP reactor can be added to handle the Contingency Case flow of 750 gpm.

8.2.2.5 Liquid Phase Carbon Adsorption V-2001 and V-2002

Treated groundwater from the advanced oxidation system PA-2001 will be pumped through liquid-phase carbon adsorption vessels (V-2001 and V-2002) (Figure 6). The liquid-phase carbon adsorption vessels V-2001 and V-2002 are provided to remove residual VOCs in extracted groundwater not otherwise destroyed by the advanced oxidation system PA-2001 to levels meeting RWQCB-LA WDR permit requirements (non-detect at effluent of lag vessel to extent practical) and residual H_2O_2 . It is expected that the liquid-phase carbon adsorption vessels will receive treated water, and therefore a small amount of carbon consumption is anticipated. The design flowrate for the liquid phase carbon adsorption vessels will be 750 gpm (the Contingency Case, Table 1).

The two liquid-phase carbon adsorption vessels will be operated in series, each filled with 20,000 pounds of virgin coconut shell based GAC. During the design phase, use of the existing two 20,000 pound liquid-phase carbon adsorption vessels at the HAC Former Building 684 site will be evaluated for use versus purchasing new liquid-phase carbon adsorption vessels.

8.2.2.6 Effluent Storage Tank T-2002

The effluent storage tank T-2002 will receive treated groundwater from the liquid-phase carbon adsorption vessels V-2001 and V-2002 (Figure 6). The effluent storage tank will be stainless steel or fiberglass. This tank will be designed and sized the same as the influent storage tank T-2001 (the Contingency Case, Table 1). The tank will include level sensors that will be used in the control system to maintain a constant level in the tank.

8.2.2.7 Injection Transfer Pump P-2002

The water from the effluent storage tank T-2002 is pumped to injection wells using injection transfer pump P-2002 (Figure 6). The transfer pump is sized to handle the Base Case 490 gpm process stream flow (Table 1). The pump pad for the injection transfer pump will be designed to accommodate a larger replacement transfer pump to handle the Contingency Case flow of

750 gpm. The transfer pump will be controlled using a VFD to match the treatment plant flowrate and the water being delivered to the injection wellfield.

8.2.2.8 Utility Storage Tank T-4001 / Transfer Pump P-4001 / Particulate Filter F-4001

The utility storage tank T-4001 will receive liquid-phase carbon backwash water, groundwater sampling and development water, injection well development water, storm water, and sump water. The utility tank T-4001 will be stainless steel or fiberglass and will be designed for atmospheric pressure operation. The storage tank will include level sensors that will be used in the control system to start and stop the transfer pump P-4001.

The water from the utility storage tank T-4001 is pumped to influent storage tank T-2001 using transfer pump P-4001 (Figure 6). The speed of the utility tank transfer pump P-4001 will be controlled using a VFD, so as not to exceed the hydraulic capacity of the treatment units downstream of influent storage tank T-2001.

Particulate filter P-4001 removes sediments prior to utility storage tank T-4001 (Figure 6). The particulate filter will be designed to remove particles 10 microns and larger and have a stainless steel housing.

8.2.3 Treatment System and Well Field Control Summary

The control system will be designed to allow unattended operation and limit the need for operator interaction. The system will allow off-site monitoring of the treatment plant, the extraction and injection wells, and will also provide for response to notifications and alarms. Overall, the treatment plant operations will be controlled using a programmable logic controller (PLC) based system at the treatment plant with local PLC systems at the extraction wells and grouped PLC control systems for on- and off-site injection wells. The PLC system at the treatment plant will communicate to local PLC systems using a fiber optic based communication. The control system will be described in greater detail through the design process.

8.2.4 Utility Requirements

The electrical service requirements for the treatment plant will be provided by Southern California Edison (SCE). The requested electrical service will be part of design. The feeder, transformer, and meter locations will be based on the technical requirements of SCE, the City of Fullerton and OCPW/FCD. The treatment system does not incorporate a redundant power supply (e.g., generators), since a power failure at the treatment plant would shut down the extraction well pumps. Battery backups are planned for critical control system components, such as alarm call outs, PLCs, computers, and emergency lighting.

Potable water is available from an existing City of Fullerton connection located at the pilot treatment plant. Potable water would be used for sanitary purposes, emergency eyewashes, and used in the treatment process for liquid phase carbon backwashes. The capacity of the existing connection will be assessed during design.

There is an existing sanitary sewer connection to the pilot treatment plant that can be used for temporary discharge of treated groundwater during maintenance activities. This connection is anticipated to be maintained. An additional connection may be required for sanitary facilities provided in the control room only which will be evaluated during the design process.

Preliminary telecommunication requirements for the treatment plant will include up to two voice lines and a data communication line. Two phone lines were selected to allow simultaneous operator communication with auto dialer alarm callout. Telecommunications services are available from Verizon and other major telecommunications service providers in the City of Fullerton.

8.3 INJECTION SYSTEM

The injection system consists of the following major elements: injection well field; conveyance pipelines and electrical as described further in the following sections.

8.3.1 Injection Well Field

The location, injection rates, injection well construction, injection tubing and injection well vaults are described in the following sections.

8.3.1.1 Injection Well Locations

The general locations of the injection wells are based upon the CMS Report (H+A, 2015). Groundwater will be injected using one existing well, MW-40 (identified as IW-2 on Figure 5); and four proposed injection wells IW-01, IW-03, IW-04 and IW-05 (Figure 5). The location of the proposed injection wells may be adjusted during design process to accommodate access constraints. It is also possible that the off-site injection well field may be eliminated if access to Sunny Ridge Drive is not feasible or practical.

At this stage in the design, alternative GW-5A serves as the Basis of Design for the locations of the injection wells (Figure 5).

8.3.1.2 Injection Rates

The Base Case injection rates for alternative GW-5A are based on CMS Report modeling and are summarized in Table 1. The total Base Case injection rate is 490 gpm. The Contingency Case injection rates for alternative GW-5A are summarized in Table 1.

The Base Case or Contingency Case injection rates are used as Basis of Design for different design elements as described in the respective sections herein and summarized in Table 1.

8.3.1.3 Injection Well Construction

One of the five injection wells have already been constructed. The four remaining injection wells will be installed by a licensed drilling contractor to the targeted injection interval. The injection well installation will be conducted in compliance with the California Department of Water Resources and California Well Standards. The design life for the new injection wells will be 30

years given the challenges in constructing deep wells in off-site locations. As such, each injection well will be constructed of stainless steel well screen and either stainless steel or high strength low alloy steel blank casing. The casing diameter will be 6 inch nominal diameter to allow installation of downhole equipment. Centralizers will be installed to center the well casing within the borehole.

Well construction details will be shown in the specifications as part of the final design.

8.3.1.4 Groundwater Injection Tubes

Groundwater injection rates for each injection well were based on the Base Case injection rates for the respective wells (Table 5). The injection tubes will be sized to inject treated groundwater from the treatment plant to the respective injection well under pressure. If higher injection rates (up to the Contingency Case) are required based on results of performance monitoring during O&M, then the injection tubing would be upsized to accomplish the increased injection rate.

Stainless steel injection tubes will be set above the screened interval and approximately 50 feet below anticipated non-injection levels accounting for seasonal variations. Injection tube depth will be included in the final design drawings.

8.3.1.5 Injection Well Vaults

Pre-cast concrete vaults will be installed around each groundwater injection wellhead. The wellhead casing will extend into the vault. Each vault lid will include an appropriate traffic-rating for protection and provide unobstructed access to the components within the vaults. The vaults will be designed to minimize surface water from entering vault. In cases where there is a high risk for surface water inflow to vault, electrical equipment will be placed in nearby above grade panels to the extent possible. Vaults will have concrete bottom to contain and detect leaks, however there will be a drain with plug to allow surface water collected during rain events to empty out, if necessary.

Injection well vault piping will be stainless steel and will transition from single-walled HDPE as the piping enters the well vault. Stainless steel piping in the vault will be sized based on the Base

Case injection rate for the respective injection well. Stainless steel pipe is the preferred material because it is rigid and resists corrosion.

The injection wells will include automated valves to control flow and which can be operated from the treatment plant PLC or the wellhead control panels. The automated valves reduce the need to physically access the wells. In addition, the water level in the injection wells will be monitored with pressure transmitters to prevent excessive water mounding and shut the control valves if the mounding exceeds set points.

8.3.2 Injection Conveyance Piping

The injection pipeline construction and pipeline routing are described in the following sections.

8.3.2.1 Injection Pipeline Construction

Single-walled HDPE pipe will be utilized for underground injection piping throughout the system. HDPE pipe is easier to install than other traditional piping materials and is cost effective, flexible, durable, and corrosion resistant. The piping shall be HDPE SDR 11 with a maximum recommended operating pressure of 160 psig at 73°F. The pipe will originate from within each vault and will convey the treated groundwater from treatment plant to each injection well. A pipeline manifold north of the treatment plant will segregate on- and off-site injection wells.

The Basis of Design for sizing pipelines incorporates Contingency Case injection rates from respective injection wells (Table 1) and maintaining pipeline velocities less than 7 feet per second. In addition, approximately four stub-out locations for future injection wells will be included on the injection pipeline on the southeastern portion of the Property.

8.3.2.2 Injection Pipeline Routing

The majority of the pipe routing will be located on the Property and within public ROWs (Figure 5). To the extent possible, routing of pipeline along arterial streets (Gilbert and Malvern)

will be minimized to reduce impact on residents/businesses and reduce traffic related risks. The routing may be refined or revised based on preliminary designs and access considerations currently being pursued with the City of Fullerton and a private HOA.

8.3.3 Injection Well Electrical Service

The on-site injection wells will have a single power source from a satellite station. Likewise, the off-site injection wells will have a single power source from a satellite station. The new satellite power stations will be located in non-traffic areas.

9.0 PROCESS FLEXIBILITY

As outlined in Section 8, the following minimum process flexibilities are required to accommodate contingencies in design and operation of treatment systems during CMI.

- The groundwater system will be designed to permit turndown to effect end of remedy operation conditions.
- The groundwater treatment system will be designed to accommodate up-scaling capacity if higher flowrates are required to achieve target pore velocities or capture zones or in the event that contingency additional extraction wells become required.
 - Below-grade groundwater piping will be sized to accommodate additional flow from contingency extraction wells, should they become required.
 - The groundwater advanced oxidation treatment system will be a modular design and additional modules can be added to accommodate the contingency flowrate, should it become necessary.
 - All submersible extraction well pumps and treatment system pumps will be operated using VFDs to allow for increases and/or decreases in flowrates to handle contingency flowrates, should they become required.
 - Spare capacity will be provided in all control panels for additional electrical loads and PLC inputs/outputs for instrumentation, should it become required.

10.0 WASTE MANAGEMENT

Best management practices for the handling of waste generated will be implemented during the construction of the proposed groundwater corrective measures. There are two kinds of waste that will be generated during the construction of the proposed corrective measures at the Site, excavated soil and runoff water. Excess excavated soil generated during the construction process is not expected to contain COCs, as such the excess excavated soil will be managed in local stock piles in accordance with applicable Storm Water Pollution Prevention Plan (SWPPP) permits for construction projects. The excess excavated soil will be sampled and hauled off site to a location/disposal facility capable of handling the soil in accordance with the sample results. In order to manage rainwater runoff, a SWPPP will be prepared as part of the construction permit process. Like excess excavated soil, rainwater runoff is not expected to contain COCs and will be managed in accordance with the approved SWPPP for construction.

In normal operations, waste streams will include treated groundwater and spent liquid-phase GAC. All waste will be disposed of in accordance with applicable operating permits or will be profiled and shipped to an off-site facility for regeneration or disposal. Wastes generated during normal operations will be managed in accordance with procedures outlined in the O&M Plan which will be prepared after the design process and major equipment has been procured (Figure 9).

11.0 REQUIRED PERMITS

Construction and operating permits will be required in order to construct and operate the proposed corrective measures at the Site. The required permits for CMI are as follows:

- Construction permits:
 - City of Fullerton Construction/Building/Encroachment Permits
 - SWPPP to support construction activities
 - Orange County Health Care Agency, Well Construction Permits
 - OCPW/OFD approved plans consistent with yet to be completed access agreement.
- Operating permits:
 - Southern California Air Quality Management District Air Discharge Permit, if required based on influent groundwater VOC concentrations at influent storage tank T-2001.
 - Orange County Sanitation District Sewer Discharge Permit
 - Los Angeles Regional Water Quality Control Board Waste Discharge Requirements Groundwater Injection Permit.
 - Orange County Health Care Agency, Hazardous Materials Business Emergency Plan for storage of H₂O₂. Note, the H₂O₂ concentration is expected to be below the Department of Homeland Security chemicals of interest.
 - OCPW/FCD, City of Fullerton and private property terms of access for O&M of the corrective measure consistent with yet to be completed access agreements.

12.0 REFERENCES

- California Environmental Protection Agency (EPA), Department of Toxic Substances Control (DTSC), 2003. Corrective Action Consent Agreement, Raytheon Company, 1901 West Malvern Ave., Fullerton, California 92634, EPA ID No. CAD063109243. Docket HWCA: P3-01/02-001. January 15, 2003.
- _____. 2018a. Letter to P. Brewer, Raytheon, from S. Rounds, DTSC, re: Approval of Resource Conservation and Recovery Act (RCRA) Corrective Measures Report (CMS) and Remedy Selection for the Raytheon Systems Company (Former Hughes Aircraft Company) 1901 West Malvern Avenue, Fullerton, California (EPA ID. No. CAD063109243). February 8, 2018.
- _____. 2018b. Statement of Basis for Raytheon Company (Former Hughes Aircraft Company) 1901 West Malvern Avenue, Fullerton, California. February 8, 2018.
- Hargis + Associates, Inc. (H+A), 2003. Additional Groundwater Assessment Work Plan (Revision 1.0), Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. April 25, 2003.
- _____. 2004. Additional Groundwater Assessment Work Plan Addendum No. 1, Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. March 23, 2004.
- _____. 2008. Additional Groundwater Assessment Work Plan Addendum No. 2, Raytheon Company (formerly Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. February 1, 2008.
- _____. 2010. Additional Groundwater Assessment Work Plan Addendum No. 3, Raytheon Company, 1901 West Malvern Avenue, Fullerton, California. October 15, 2010.
- _____. 2011. Additional Groundwater Assessment Work Plan Addendum No. 4, Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. April 13, 2011.
- _____. 2013a. Additional Groundwater Assessment Work Plan Addendum. No.5, Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. February 22, 2013.
- _____. 2013b. Additional Groundwater Assessment Work Plan Addendum No. 6, Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. December 19, 2013.
- _____. 2014. Additional Groundwater Assessment and Monitor Well Construction Report (MW-41) Raytheon Company, 1901 West Malvern Avenue, Fullerton, California. December 2, 2014.
- _____. 2015. Corrective Measures Study, Raytheon Company (former Hughes Aircraft Company), 1901 West Malvern Avenue, Fullerton, California. June 11, 2015.

- _____, 2017. Letter to S. Rounds, DTSC from C. Ross, K. Coons and S. Netto, H+A, re: Revision 1 of Addendum1: Plan to Address Potential Discovery of Pre-Historic or Historic-Era Materials, Corrective Measures Study Report, Former Raytheon Company (Formerly Hughes Aircraft Company) Site, 1901 West Malvern Avenue, Fullerton, California. August 8, 2017.
- _____, 2018. Letter to S. Rounds, DTSC, from S. Netto, T. Evans and S. Stewart, H+A, re: Data Submittal for Groundwater Monitoring and Groundwater Extraction and Treatment Pilot Testing, Fourth Quarter 2017, Raytheon Company (Former Hughes Aircraft Company) Facility, 1901 West Malvern Avenue, Fullerton, California. January 10, 2018.

TABLE 1
BASE AND CONTINGENCY CASE FLOWRATES, BASIS OF DESIGN

LOCATION	WELL IDENTIFIER	ALTERNATIVE GW5A (gpm)		BASIS OF DESIGN FOR RESPECTIVE ELEMENT										
				EXTRACTION/INJECTION SYSTEMS					TREATMENT SYSTEM					
				WELL		DROP PIPE	PIPELINE	ELECTRICAL	INFLUENT CONCENTRATION ¹	COMPONENT (FLOW)				
		BC	CC	DIAMETER	PUMP					Tanks T2001 / T2002	Filters F2001 / F4001	AOP PA2001	GAC V2001 / V2002	Transfer Pumps
On-Property	MW-21	10	20	Existing	BC		CC	CC	BC ³					
	EW-01	10	20	Existing	BC		CC	CC	BC ³					
	EW-02	120	180	Existing	BC		CC	CC	BC ³					
	MW-29	20	40	Existing	BC		CC	CC	BC ³					
	MW-31	20	60	Existing	BC		CC	CC	BC ³					
	EW-07	10	20	CC ⁶	BC		CC	CC	BC ³					
Off-Property	EW-03	100	200	CC ⁶	BC		CC	CC	BC ³					
	EW-04	100	200	CC ⁶	BC		CC ⁴	CC	BC ³					
	EW-06	100	200	CC ⁶	BC		CC	CC	BC ³					
Both	TOTAL	490	750 ⁷							1.5 x BC	1.5 x BC	BC	1.5 x BC	BC
On-Property	SEWER	50 ⁵	NA	Existing										
NA	RECLAIM	NA	NA	NA										
On-Property	IW-01	95	200 ²	CC ^{2,6}		BC	CC ²							
	MW-40	95	200 ²	Existing		BC	CC ²							
Off-Property	IW-03	100	100	BC ⁶		BC	BC							
	IW-04	100	100	BC ⁶		BC	BC							
	IW-05	100	100	BC ⁶		BC	BC							

¹ Influent concentration to treatment system is based on base case extraction rates and associated estimated concentrations (see Table 2).

² Contingency injection capacity reserved for on-Property injection wells, which can include future injection wells (4 additional pipeline stub outs), total flow 600 gpm.

³ Influent concentration to treatment system will also consider temporary shut down of high-flowrate, low-concentration extraction well to confirm system can handle upsets.

⁴ Cumulative off-property extraction rate limited to 600 gpm, however, pipeline from EW-04 to EW-03 to be sized for 400 gpm and EW-03 to Burning tree to be sized for 500 gpm.

⁵ Existing sewer connection to be kept for maintenance activities, the nominal capacity is 50 gpm, but use would be infrequent.

⁶ Minimum well casing diameter is 6-inches inside casing diameter to provide space for downhole equipment.

⁷ Treatment system Contingency Case capacity (750 gpm) is capped at 150% of Base Case flow (490 gpm); increasing all wells simultaneously to Contingency Case flow rates is a remote possibility.

BC = Base Case

CC = Contingency Case

gpm = Gallons per minute

NA = Not applicable

AOP = Advanced oxidation process

GAC = Granular activated carbon

TABLE 2
BASE AND CONTINGENCY CASE CONCENTRATIONS, BASIS OF DESIGN

LOCATION	WELL IDENTIFIER	FLOWRATE (gpm)		CONCENTRATION (ug/l)					BASIS OF DESIGN	
		BC ¹	CC ²	BASIS ³	1,1-DCE	1,1-DCA	TCE	1,4-Dioxane	AOP PA2001	GAC V2001 / V2002
On-Property	MW-21	10	10	Well	2,000	30	20	300		
	EW-01	10	10	Well	400	5	1	300		
	EW-02	120	120	Well	50	1	1	30		
	MW-29	20	20	Well	400	4	4	200		
	MW-31	20	20	Well	200	2	9	4		
	EW-07	10	10	MW-8	30	1	140	7		
Off-Property	EW-03	100	100	MW-32B, MW-34B, MW-36	200	2	20	40		
	EW-04	100	100	MW-36	200	2	1	6		
	EW-06	100	0	MW-33	10	1	1	1		
Both	TOTAL	490	390							
	ESTIMATED BC CONCENTRATION ⁴				200	3	9	40		
	ESTIMATED CC CONCENTRATION ⁴				300	3	20	50	X ⁵	X ⁵

¹ Base case flowrate (see Table 1).

² Contingency case same as base case, except low concentration well is off.

³ Influent concentration based on average of samples collected from respective wells. The average is rounded up to one significant figure.

⁴ Total influent concentration based on concentration and flowrate for each extraction well rounded up to one significant figure.

⁵ Basis of Design will be concentrations specified in this table and flowrates specified in Table 1.

BC = Base Case

CC = Contingency Case

gpm = Gallons per minute

ug/l = Micrograms per liter


AOP = Advanced oxidation process

GAC = Granular activated carbon

1,1-DCE = 1,1-Dichloroethylene


1,1-DCA = 1,1-Dichloroethane

TCE = Trichloroethylene



HARGIS+ASSOCIATES, INC.
Hydrogeology/Engineering

FIGURE 1. SITE LOCATION



Jul 18, 2016 - 9:41am ADH - T:\2016\500-599\532 Raytheon\Hydrogeology\Water LV\220-2341.dwg

FIGURE 3.
CONCEPTUAL SITE MODEL OVERVIEW, UNIT B/TARGET ZONE



Apr 09, 2018 - 2:14pm adh - \\SANDIEGO-FS01\dfs\sandiego\H+A GRAPHIC-FILES\2018\500-599\532 Raytheon\Engineering\Civil\550-1135.dwg





FIGURE 5.
RECOMMENDED GROUNDWATER CORRECTIVE MEASURE





EXPLANATION

AOP ADVANCED OXIDATION PROCESS
GPM GALLONS PER MINUTE

FIGURE 6. ALTERNATIVE GW5A: ON-SITE AND BREA CREEK ALIGNMENT EXTRACTION WITH ON-SITE AND OFF-SITE UNIT B INJECTION SIMPLIFIED PROCESS FLOW DIAGRAM


Apr 11, 2018 - 6:27pm ESS - T:\2017\500-599\532 Raytheon\Hydrogeology\H+A Base\laps\410-9833.dwg



HARGIS + ASSOCIATES, INC.
Hydrogeology/Engineering

FIGURE 7.
REGIONAL PRODUCTION WELLS
























**ORGANIZATIONAL STRUCTURE FOR CORRECTIVE MEASURES IMPLEMENTATION
FORMER RAYTHEON (FORMERLY HAC) FACILITY, 1901 WEST MALVERN AVENUE, FULLERTON, CALIFORNIA**



FOOTNOTES:

HAC = Hughes Aircraft Company
EHS = Environment, Health and Safety
PG = Professional Geologist
PE = Professional Engineer
CHG = Certified Hydrogeologist

FIGURE 8. ORGANIZATIONAL CHART

TASK	ANTICIPATED DURATION (MONTHS)	FROM MILESTONE	DELIVERABLES	CONCEPTUAL SEQUENCING			
				2018	2019	2020	2021+
Corrective Measures Study (CMS)	Complete						
Corrective Measures Implementation (CMI)							
Pilot Test OMM	On-Going	Operate through start of construction	Quarterly data submittals and annual report to DTSC				
CMI Work Plan							
Submit to DTSC	Complete	Approval of CMS	CMI Work Plan to DTSC				
DTSC Review and Approval	2	Submittal of CMI work plan	Approval from DTSC				
Finalize Terms of Access Agreements							
Brea Creek	6	On-going	Terms of access between OCPW/FCD and Raytheon				
Fullerton Rights of Way	4	On-going	Terms of access between City of Fullerton and Raytheon				
Private Property	4	Receipt of draft agreements for Brea Creek and rights of way	Terms of access between home owners association and private party and Raytheon				
Design							
60 Percent	4	Receipt of final terms of access	Submittal to DTSC, DTSC review concurrent with 90 percent design				
90 Percent	2	60 percent design	Submittal to DTSC, DTSC review concurrent with 100 percent design				
100 Percent	1	90 percent design	Submittal to City of Fullerton and OCPW/FCD for construction permit. Provided to DTSC for informational purposes.				
Plans and Specifications	3	60 percent design	Specifications provided to DTSC for informational purposes				
Updated cost estimate	3	90 percent design	Cost estimate for construction and O&M to DTSC				
Construction							
Construction Work Plan	Not applicable	Integrated into specifications	None				
Wells	6	Receipt of construction permits following 100 percent design and access agreements	Use existing CMS Work Plan and QAPP for monitor well construction. Plans and specifications will include details for extraction/injection well construction.				
Pipelines and electrical	12	Receipt of construction permits/access agreements and contracting	As built drawings				
Fabricate Major Treatment Equipment	6	Receipt of construction permits	None				
Treatment System	6	Receipt of building permit, integrated receipt of major treatment system equipment	As built drawings				
Construction Completion Report	3	Completion of construction	Summary document principally containing as-built drawings submitted to City of Fullerton, OCPW/FCD, private parties and DTSC				
Operating Permits and Plan							
Confirm performance specifications	3	CMI Work Plan submittal	None, meetings with RWQCB, OCHCA, City of Fullerton and OCPW/FCD				
Obtain operating permits	6	Receipt of major treatment equipment specifications	RWQCB WDR permit, OCHCA HMBEP, OCSD and applicable access agreements				
Operation and Maintenance (O&M) Plan	4	Receipt of major treatment equipment specifications	Submittal to DTSC				
Approval of O&M Plan	2	Submittal of O&M Plan	Approval from DTSC				
OMM							
Start-Up	3	Completion of construction	None				
Normal O&M	Long-Term	Completion of Start-Up	Periodic O&M and monitoring reports to DTSC and permitting agencies				
Reclaim End Use	Future	To be determined					

DTSC = California Department of Toxic Substances Control
OCPW/FCD = Orange County Department of Public Works, Flood Control District
HMBEP = Hazardous Materials Business Emergency Plan
RWQCB = California Regional Water Quality Control Board, Santa Ana Region
QAPP = Quality Assurance Project Plan

OCHCA = Orange County Health Care Agency
WDR = Waste Discharge Requirement
OCSD = Orange County Sanitation District
OMM = Operations, Maintenance and Monitoring

FIGURE 9. CORRECTIVE MEASURES IMPLEMENTATION SCHEDULE




FIGURE 10. ALTERNATIVE GW6A: ON-SITE AND SOUTH OF BREA CREEK EXTRACTION WITH ON- AND OFF-SITE DISTRIBUTED INJECTION